

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/DFS/MS/School/2024/WZ/127

Dated: 22/02/2024

FIRE SAFETY CERTIFICATE

Certified that the **Remal Public Senior Sec. School, Blk-A, Pkt-2, Sec-3, Rohini, Delhi-85** comprised of **Ground and 03 upper floors** owned/ occupied by **Remal Public Senior Sec. School** was issued Fire Safety Certificated vide this office letter no. **F.6/DFS/MS/School/2020/WZ/22 dated 08.01.2021**. The premise was re-inspected by the officer concerned of this department on **15.02.2024** in the presence of **Mr. Rohit Bajaj (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from 22/02/2024 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,.

Issued on 22/02/2024..... at New Delhi

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 110054.
2. The Manager, Remal Public Senior Sec. School, Blk-A, Pkt-2, Sec-3, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in